

Test Verification of Conformity

Verification Number: 210909082GZU-VOC005

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the regulation(s) listed on this verification at the time the tests were carried out. Other standards and Regulations may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CA** mark regulations are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address: Shenzhen Growatt New Energy Co., Ltd.

2F and 3F, Building 4, Jiayu Company Industrial Park, Xibianling, Shangyu Village, Shiyan

Street, Bao'an District, Shenzhen, China

Product Description: PV Grid inverter& Hybrid inverter

Models/Type References: MIN 2500TL-XE, MIN 3000TL-XE, MIN 3600TL-XE, MIN 4200TL-XE,

MIN 4600TL-XE, MIN 5000TL-XE, MIN 6000TL-XE

MIN 2500TL-XH, MIN 3000TL-XH, MIN 3600TL-XH, MIN 4200TL-XH,

MIN 4600TL-XH, MIN 5000TL-XH, MIN 6000TL-XH

Ratings & Principle See Appendix

Characteristics: **Brand Name:** Growatt

Relevant EN 61000-6-1:2007

Standards/Regulations: EN 61000-6-3:2007+A1:2011

EN 61000-6-2:2005

EN 61000-6-4:2007+A1:2011

Electromagnetic Compatibility Regulations 2016

Verification Issuing Office Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Name & Address:

Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2.

Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China

Date of Tests:

Test Report Number(s): 181016129GZU-003 Amendment 1 181016129GZU-004 Amendment 1

Additional information in Appendix.

Signature

Name: Sky Zhu

Position: Team Leader Date: 01 December 2021

conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, roduct or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program



APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210909082GZU-VOC005

Model	MIN 2500TL-XE	MIN 3000TL->	ΚE	MIN 3600TL-XE	MIN 4200TL-XE	
	MIN 2500TL-XH	MIN 3000TL->	ΚΗ	MIN 3600TL-XH	MIN 4200TL-XH	
Max.PV voltage	500 d.c.V			550 d.c.V		
PV voltage range	80-500 d.c.V (only for MIN 2500TL- XE, MIN 3000TL-XE) 70-500 d.c.V (only for MIN 2500TL-		P	XE, MIN 4200TL-XE)		
	XH, MIN 3000TL-XH)			XH, MIN 4200TL-XH)		
PV Isc	16.9 d.c.A*2					
Max.input current	13.5 d.c.A*2					
Max. DC voltage	500 d.c.V (only fo XH, MIN 300			550 d.c.V (only for MIN 3600TL-XH, MIN 4200TL-XH)		
DC voltage range		360-500 d.c.V (only for MIN 2500TL-XH, MIN 3000TL-XH)		360-550 d.c.V (only for MIN 3600TL-XH, MIN 4200TL-XH)		
Max. DC current	17 d.c.A (only for MIN 2500TL-XH, MIN 3000TL-XH, MIN 3600TL-XH, MIN 4200TL-XH)					
Max.output power	2500W	3000W		3600W	4200W	
Max.apparent power	2500VA	3000VA		3600VA	4200VA	
Nominal output voltage	230 a.c.V					
Max.output current	11.3 a.c.A	13.6 a.c.A	A	16 a.c.A	19 a.c.A	
Nominal output Frequency	50/60Hz					
Power factor range	0.8Leading – 0.8 lagging					
Safety level	Class I					
Ingress Protection	IP 65					
Operation Ambient Temperature	-25℃ - +60℃					
Software version	AL 1.0					

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Model	MIN 4600TL-XE	MIN 5000TL-XE	MIN 6000TL-XE			
	MIN 4600TL-XH	MIN 5000TL-XH	MIN 6000TL-XH			
Max.PV voltage	550 d.c.V					
PV voltage range	80-550 d.c.V (only for MIN 4600TL-XE, MIN 5000TL-XE, MIN 6000TL-XE)					
	70-550 d.c.V (only for MIN 4600TL-XH, MIN 5000TL-XH, MIN 6000TL-XH)					
PV Isc	16.9 d.c.A*2					
Max.input current	13.5 d.c.A*2					
Max. DC voltage	550 d.c.V (only for MIN 4600TL-XH, MIN 5000TL-XH, MIN 6000TL-XH)					
DC voltage range	360-550 d.c.V (only for MIN 4600TL-XH, MIN 5000TL-XH, MIN 6000TL-XH)					
Max. DC current	17 d.c.A (only for MIN 4600TL-XH, MIN 5000TL-XH, MIN 6000TL-XH)					
Max.output power	4600W	5000W	6000W			
Max.apparent power	4600VA	5000VA	6000VA			
Nominal output voltage	230 a.c.V					
Max.output current	20.9 a.c.A	22.7 a.c.A	27.2 a.c.A			
Nominal output Frequency	50/60Hz					
Power factor range	0.8Leading – 0.8 lagging					
Safety level	Class I					
Ingress Protection	IP 65					
Operation Ambient Temperature	-25℃ - +60℃					
Software version	AL 1.0					

Signature

Name: Sky Zhu

Position: Team Leader Date: 01 December 2021

Sky 2hu