



## CERTIFICATE OF ANALYSIS

Fugro GB Marine Limited  
Trafalgar Wharf (Unit 16)  
Hamilton Road  
Portchester  
Portsmouth  
PO6 4PX  
United Kingdom

Date: 23/03/2017

Our Ref: 172013\_ Horizon

15/03/2017

Dear Marie Wilkinson,

Please find attached analysis results and certificates for the samples taken on 15/03/2017 from sample location: Horizon.

Test ID	Method Ref.	UKAS	Result	Units
TCOL	10.11, 10.12	Yes	0	cfu/100ml
ECOL	10.11, 10.12	Yes	0	cfu/100ml
PSAER	10.07	Yes	0	cfu/100ml
TVC_1D37	10.04	Yes	0	cfu/ml
CHLORINE_Free	N/A	No	0.94	mg/l
CHLORINE_Total	N/A	No	1.60	mg/l
CHLORINE_Combined	N/A	No	0.66	mg/l
pH	N/A	No	7.50	pH units
TEMP	N/A	No	29.1	°C
ALKALINITY	TM04_001	No	90	mg/l

### Comments:

WATERLOOVILLE MAIN POOL - Swim club taking place. Sample and in-situ readings taken by client.  
Microbiological results acceptable - no action required.

Yours sincerely,

**James Hutchinson**

**Technical Manager - Microbiological Sampling Services**